



中国国家强制性产品认证证书

证书编号：2024010307652216

认证委托人名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产者名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称及地址

浙江九策智能电气有限公司
浙江省乐清市柳市镇东风工业区奋进路5号

产品名称和系列、型号、规格

漏电断路器

TGBDLE-80Y、TGBDLE-80YH; U_i :500V; U_{imp} :4kV; U_e : AC230V; I_n : 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A; 瞬时脱扣类型: C、D 型特性; $I_{\Delta n}$: 15mA、30mA、50mA、100mA、300mA; 额定剩余动作类型: AC、A 型, 电子式; $I_{\Delta m}$: 2000A; TGBDLE-80Y: $I_{cn}=I_{cs}$: 6kA; TGBDLE-80YH: I_{cs} : 7.5kA, I_{cn} : 10kA; 极数: 1P+N(一个保护极, N 极可开闭)、2P; 适用于隔离用;

产品标准和技术要求

GB/T 16917.1-2014; GB/T 16917.22-2008

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》(CNCA-C03-02:2024)的要求, 特发此证。

发证日期: 2024年07月03日 有效期至: 2029年06月17日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验, 也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010307652216

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Zhejiang Jiuce Intelligent Electric Co.,Ltd.
NO. 5, Fenjin Road, Dongfeng Industrial Zone, Liushi Town, Yueqing City, Wenzhou City, Zhejiang Province

PRODUCT NAME,MODEL AND SPECIFICATION

Leakage Circuit Breaker

TGBDLE-80Y、TGBDLE-80YH ; U_i :500V ; U_{imp} :4kV ; U_e : AC230V ; I_n : 6A , 10A , 16A , 20A , 25A , 32A , 40A , 50A , 63A , 80A ; Type of Instantaneous Tripping Current : C、D ; $I_{\Delta n}$:15mA、30mA、50mA、100mA、300mA ; Rated Residual Operating Type : AC、A , Electronic Residual Current Tripping Unit ; $I_{\Delta m}$: 2000A ; TGBDLE-80Y : $I_{cn}=I_{cs}$: 6kA ; TGBDLE-80YH : I_{cs} : 7.5kA , I_{cn} : 10kA ; Poles : 1P+N(With one protective poles,Switched N pole)、2P ; Suitable for isolation;

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 16917.1-2014;GB/T 16917.22-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.03,2024

Valid until: Jun.17,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

